



**JAY R. SMITH MFG. CO.**  
 MEMBER OF ACORN'S FAMILY OF COMPANIES  
 POST OFFICE BOX 3237  
 MONTGOMERY, ALABAMA 36109-0237 (USA)  
 TEL: 334-277-8520 FAX: 334-272-7396 www.jrsmith.com



MEMBER OF:



LOCATION

# MILD CLIMATE ANTI-SIPHON SILLCOCK

**FUNCTION:** For installation in interior and exterior wall locations of buildings that are not subject to freezing. Vacuum breaker prevents contamination of potable water supply and conforms to the requirements of ASSE Standard 1011.




Fig. 5672.....1/2"(13) Inlet




Fig. 5673.....3/4"(19) Inlet

**NOTES:**

1. The AB1953, California Lead Law, and NSF/ANSI Standard 61-2008 - Drinking Water Components are not applicable to Jay R. Smith hydrants as they do not convey/dispense water for human consumption through drinking or cooking.
2. Dimensions shown in parentheses are in millimeters.

**REGULARLY FURNISHED:**

Hose Valve has a Rough Finish Brass Body  
 Removable Wheel Handle, "T" Handle Key,  
 NPT Female Threaded Inlet Size Indicated  
 by Figure Number Selected and ASSE 1011  
 Vacuum Breaker with 3/4"(19) Hose Connection.

**OPTIONAL MATERIALS:**

Rough Chrome Plated -CR

**NOTE:** Dimensions shown in Parentheses are in millimeters.

DRAWING NUMBER  
5672, 5673

SIZE  
A

SCALE:  
NONE

DATE:  
6-17-11

APPROVED BY:  
CL

CHECKED BY:  
CL

DRAWN BY:  
TBW

5672, 5673

FIGURE NUMBER

DIMENSIONS ARE SUBJECT TO MANUFACTURERS TOLERANCE AND CHANGE WITHOUT NOTICE

REV.	DATE	DESCRIPTION	BY	CKD. BY	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER
							<b>5672, 5673</b>