


- NOTES:
1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions. Engineering advice may be required.
  2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
  3. The finished level of the concrete surround must be approx. 1/8" (3) above the top of the channel edge.
  4. Refer to SMITH/ACO'S latest installation instructions for complete details.
  5. Concrete base thickness should match slab thickness.

## SMITH DRAINAGE SYSTEMS

SMITH



CUSTOMER  
DRIVEN

JAY R. SMITH MFG CO.®  
DIV. OF SMITH INDUSTRIES  
MONTGOMERY, AL

WWW.JRSMITH.COM

# INSTALLATION DRAWING

## 9810 SERIES TRENCH DRAIN-LOAD CLASS E INSTALLED IN ASPHALT

PM-1401