


**NOTES:**

1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions. Engineering advice may be required.
2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
3. The finished level of the concrete surround must be approx. 1/8" (3) above the top of the channel edge.
4. Refer to SMITH/ACO's latest installation instructions for complete details.
5. Concrete base thickness should match slab thickness.

**SMITH DRAINAGE SYSTEMS**

**SMITH**



CUSTOMER  
DRIVEN™

JAY R. SMITH MFG CO.®  
DIV. OF SMITH INDUSTRIES  
MONTGOMERY, AL

WWW.JRSMITH.COM

# INSTALLATION DRAWING

9812 SERIES TRENCH DRAIN-LOAD CLASS E

INSTALLED IN ASPHALT

PM-1414