



- NOTES:
1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions. Engineering advice may be required.
 2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
 3. Pavers to be 1/8" (3) above channel edge. A bead of sealant can be used between the rail & concrete.
 4. Refer to SMITH/ACO's latest installation instructions for complete details.
 5. Concrete base thickness should match slab thickness.

SMITH DRAINAGE SYSTEMS



JAY R. SMITH MFG CO.®
DIV. OF SMITH INDUSTRIES
MONTGOMERY, AL
WWW.JRSMITH.COM

INSTALLATION DRAWING
9818 SERIES TRENCH DRAIN
WITH BRICKSLOT GRATE-LOAD CLASS C
INSTALLED WITH PAVERS

PM-1423