


- NOTES:
1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions. Engineering advice may be required.
  2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
  3. The finished level of the concrete surround must be approx. 1/8" above the top of the channel edge.
  4. Refer to SMITH/ACO's latest installation instructions for complete details.
  5. Where used within a suspended slab, engineering advice must be sought.
  6. Concrete base thickness should match slab thickness.

**SMITH DRAINAGE SYSTEMS**

**SMITH**



CUSTOMER  
DRIVEN\*

JAY R. SMITH MFG CO.®  
DIV. OF SMITH INDUSTRIES  
MONTGOMERY, AL

WWW.JRSMITH.COM

**INSTALLATION DRAWING**  
**9832-0100 SERIES TRENCH DRAIN-LOAD CLASS A-C**  
**INSTALLED WITH ASPHALT**

**PM-1437**