



NOTES:

1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions. Engineering advice may be required.
2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
3. The finished level of the concrete surround must be approx. 1/8" (3) above the top of the channel edge.
4. Refer to SMITH/ACO'S latest installation instructions for complete details.
5. Where used within a suspended slab, engineering advice must be sought.
6. The paver course adjacent to the channel edge must be fully bonded to the concrete surround.

SMITH DRAINAGE SYSTEMS

SMITH



CUSTOMER  
DRIVEN\*

JAY R. SMITH MFG CO.®  
DIV. OF SMITH INDUSTRIES  
MONTGOMERY, AL

WWW.JRSMITH.COM

# INSTALLATION DRAWING

## 9832-0100 SERIES TRENCH DRAIN-LOAD CLASS A-C INSTALLED WITH PAVERS

PM-1439