


- NOTES:
1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions. Engineering advice may be required.
 2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
 3. The finished level of the concrete surround must be approx. 1/8" (3) above the top of the channel edge.
 4. Refer to SMITH/ACO's latest installation instructions for complete details.
 5. Where used within a suspended slab, engineering advice must be sought.
 6. Concrete base thickness should match slab thickness.

SMITH DRAINAGE SYSTEMS

SMITH



CUSTOMER
DRIVEN*

JAY R. SMITH MFG CO.®
DIV. OF SMITH INDUSTRIES
MONTGOMERY, AL

WWW.JRSMITH.COM

INSTALLATION DRAWING

9833 SERIES TRENCH DRAIN - LOAD CLASS A-C

INSTALLED IN ASPHALT

PM-1440